Cylinder & Compressed Gas Signs, continued




7" x 10" MCPG814
10" x 14" MCPG812



14" x 10" MCPG803



14" x 10" MCPG815



14" x 10" MCPG807




10" x 14" MCPG808



10" x 14" MCPG501

§ 1910.253 (c)(3)(v) Oxygen-fuel gas welding and cutting.



10" x 14" MCPG507



14" x 10" MCPG504

DOT 49 CFR 172.330(c)



7" x 17" MCPG509
(2" Letters)



10" x 7" MCPG503
14" x 10" MCPG506



10" x 14" MCPG502



4" x 12" MCPG505



7" x 10" MCPG562
10" x 14" MCPG531



7" x 10" MCPG563
10" x 14" MCPG532



7" x 10" MCPG564
10" x 14" MCPG533



7" x 10" MCPG565
10" x 14" MCPG534



7" x 10" MCPG566
10" x 14" MCPG535



7" x 10" MCPG567
10" x 14" MCPG536



10" x 14" MCPG520



7" x 10" MCPG588
10" x 14" MCPG529



7" x 10" MCPG583
10" x 14" MCPG527



10" x 14" MWLD518



10" x 14" MWLD514



7" x 10" MCPG595
10" x 14" MCPG596



10" x 14" MCPG510



7" x 10" MCPG598
10" x 14" MCPG594



7" x 10" MCPG589
10" x 14" MCPG526



7" x 10" MCPG585
10" x 14" MCPG530



14" x 10" SBMCPG526



10" x 14" MWLD506



10" x 14" MWLD502



10" x 14" MWLD510



7" x 10" MCPG584
10" x 14" MCPG523



10" x 14" MWLD520



10" x 14" MWLD516



7" x 10" MCPG593
10" x 14" MCPG597



10" x 14" MCPG515



7" x 10" MCPG600
10" x 14" MCPG599



7" x 10" MCPG586
10" x 14" MCPG525



14" x 10" SBMCPG525

10" x 14" MWLD508

10" x 14" MWLD504

10" x 14" MWLD512

7" x 10" MCPG568
10" x 14" MCPG537

7" x 10" MCPG569
10" x 14" MCPG538

7" x 10" MCPG570
10" x 14" MCPG539

7" x 10" MCPG571
10" x 14" MCPG540

7" x 10" MCPG576
10" x 14" MCPG545

7" x 10" MCPG572
10" x 14" MCPG541

7" x 10" MCPG573
10" x 14" MCPG542

7" x 10" MCPG512
10" x 14" MCPG513

7" x 10" MCPG514
10" x 14" MCPG518

INL CG 3.4.4.4 Cylinders shall be securely restrained to a firm structure, at about two-thirds their height.

INL CG 3.3.2 Valves shall be closed, regulators shall be removed, and valve-protection caps shall be installed (when provided) before cylinders are moved, unless the cylinders are firmly secured on a special carrier intended for this purpose and the valves are protected.

INL CG 3.3.4 Magnets or choker slings shall not be used to hoist or transport individual cylinders.